

MINI WEB SERVER	Mini WEB SERVER Settings			GATEWAY "LOCAL"	Network Settings		Modbus RS485 Settings				
	IP Address ^[1]	Subnet Mask ^[1]	Default Gateway ^[1]		IP Address		Mode	Parity ^[1]	Stop Bits ^[1]	Speed ^[1]	Timeout RS485 ^[1]
					127.0.0.1		RTU				

GATEWAY	Network Settings			Bus Modbus RS485 Settings					Settings			
	IP Address ^[1]	Subnet Mask ^[1]	Default Gateway ^[1]	Mode ^[1]	Parity ^[1]	Stop Bits ^[1]	Speed ^[1]	Timeout RS485 ^[1]	Name ^[1]	Description / Location	Panel Board	EQ Device

Note: If you use Mini Web Server also as Gateway, you have to use a specific parameter table for the gateway "Local".

DEVICE	DEVICE Settings										
No.	Model ^[1]	Modbus Address ^[1] (Modbus Address-Position ^[2])	Name ^[1]	Exclude from totals ^[3]	CT Ratio (ex. .../5A or .../1A)	Load	Measure Group 1	Measure Group 2	Measure Group 3	Measure Group 4	Measure Group 5
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
32											

Details for Pulse Output Meters		
Model ^[1]	Modbus Address ^[1]	Position ^[2]
Counter model	Modbus address of the Concentrator	Corresponds at the input number of the Concentrator on which the counter is connected!

Details for "Exclude from totals" ^[3]
Use this option if you want that consumptions of the selected device is not included in the pages "Total" and "Partial" of the menu "Consumption." This consumptions will always be displayed on the page "Details".

LEGEND
^[1]Required Parameters
^[2]Required Parameter only for Pulse Output Meters
^[3]Optional parameter only for measuring devices

NOTE: for more details refer to the user manual

