

GATEWAY	Network Settings			Bus RS485 Settings				Settings			
	IP Address <sup>[1]</sup>	Subnet Mask <sup>[1]</sup>	Default Gateway <sup>[1]</sup>	Mode <sup>[1]</sup>	Parity <sup>[1]</sup>	Stop Bits <sup>[1]</sup>	Speed <sup>[1]</sup>	Timeout RS485 <sup>[1]</sup>	Name <sup>[1]</sup>	Description / Location	Panel Board

**Note:** max. 32 Modbus addresses or Pulse counters for each Gateway. In case of several Gateways, use a parameter table for each gateway.

DEVICE												
DEVICE Settings												
No.	Model <sup>[1]</sup>	Modbus Address <sup>[1]</sup> (Modbus Address-Position <sup>[2]</sup> )	Name <sup>[1]</sup>	Exclude from totals <sup>[3]</sup>	CT Ratio (ex. .../5A or .../1A)	Load	Measure Group 1	Measure Group 2	Measure Group 3	Measure Group 4	Measure Group 5	
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												

Details for Pulse Output Meters		
Model <sup>[1]</sup>	Modbus Address <sup>[1]</sup>	Position <sup>[2]</sup>
Counter model	Modbus address of the Concentrator	Corresponds at the input number of the Concentrator on which the counter is connected!

**Details for "Exclude from totals"<sup>[3]</sup>**  
 Use this option if you want that consumptions of the selected device is not included in the pages "Total" and "Partial" of the menu "Consumption." This consumptions will always be displayed on the page "Details".

LEGEND  
<sup>[1]</sup>Required Parameters  
<sup>[2]</sup>Required Parameter only for Pulse Output Meters  
<sup>[3]</sup>Optional parameter only for measuring devices

**NOTE: for more details refer to the user manual**

